

# DEMIN VII KNOWLEDGE SHARING

EXPERIENCE from X-RAY FACILITIES
VIBRATION MANAGEMENT

Compiled by I. Sutton on behalf of the 'vibration and alignment working group'

### Overview

- Group
  - Cross facility SLS / Swissfel
  - Survey / alignment / metrology / vibration
- Scale of beamlines is equivalent to neutron facilties
  - X-ray beamlines 36m
  - Fel beamlines 150m
- Resultant issue
  - Beam dances on samples (1micron beam)
- Management strategy
  - Mount all beamlines rigidly to slab (1 slab 700m)
  - Design structures for high natural frequencies
  - Create a quiet environment defined objective / monitor (class Vc-d)

## Methods of V. Control

#### Monitoring

- Systems installed at both facilities. cost 2-10kE
- Data is taken continuously
- Streamed and available to instruments (SLS) may be used for data veto
- Streamed and recorded (SFEL), wait for problems

#### Principal issues

- Off site
  - Heavy industrial machines (low frequencies)
- On site
  - Crane, water pumps, aircon

## Alignment

#### Hydrostatic height measurement

#### General alignment

Lazer tracker

#### Monitoring

- Beamlines equiped for position monitoring and remote adjustment.
- Ground movement is minimal (<1mm) and system is rarely used.</li>
- Issues with reliability of monitoring system.



High precision height adjuster

## Relevance to neutron instruments

#### General case neutron optics

- no performance issue.
  - Neutrons use big moderators, big beams, big samples and multiple bounces wash out the effects of minor vibrations
  - Vibration less significant than alignment errors

#### Special case

- Parabolic geometries (small beams, few bounces)
- Liquid reflectometers
- Precautions may be required

### Relevance to neutron instruments

Local earthquakes (aka Choppers / pumps / etc)

Neutron instruments 'local causes' notable heavy choppers may be the greatest sources of vibration and concern.

Transmission of vibrations through the slab to neighboring instruments a potential issue.

Unclear whether 'bolted down' or an 'isolator' strategy would be more effective.

Magnetic bearing on equipment is believed to significantly reduce vibrations issues.

For facilities with long guides the installation of a vibration monitoring system is recommended for diagnostic purposes

## Elephants and mice

**Neutron scattering** X-ray scattering instruments Instruments Big beams Small beams Internal External sources sources **Vibration** Vibration monitoring management **Bolt down** Bolt down or isolate? Stiff and light

both mammals ... things to learn